

**TEST CERTIFICATE**

Date of Reporting : 11/03/2020

Sample Sending Authority/Person : VIJOY VIR SINGH, PRICIPAL, KENDRIYA VIDYALAYA, BERHAMPORE (W.B.)

Sl. Memo No : F.25224/2019-20 Dated-03/03/2020

Location Details : KENDRIYA VIDYALAYA, BERHAMPORE (W.B.)

Date of Sampling: 03/03/2020

Sample Collected by : AGENCY

Type of Sample : PERMIT WATER

**Physical, Chemical & Bacteriological Test Finding:**

Sl.No.	Parameter	Desirable Limit*	Permissible Limit in absence of alternate Source *	Test Result
1.	pH	6.5-8.5	No Relaxation	7.33
2.	Turbidity( NTU)	1	5	1.00
3.	T.D.S.(mg/l)	500	2000	-
4.	Total Hardness(as CaCO <sub>3</sub> ),mg/l)	200	600	20
5.	Arsenic(mg/l)	0.01	No Relaxation	0.001
6.	Iron(mg/l)	0.3	1.0	0.01
7.	Manganese(mg/l)	0.1	0.3	0.02
8.	Total Coliform (CFU/100ml)	Absent	Absent	Absent
9.	Faecal Coliform (CFU/100ml)	Absent	Absent	Absent

\* Drinking Water- Bureau of IndianStandars (BIS) IS:10500:2012,Drinking Water Specification 2012 an Amendment No. 1 JUNE 2015.

\* BDL= Below Detectable Limit.

\* Remarks: Water Test report shows all the parameters tested are well within permissible limit hence the said water is fit for human consumption.

Signature of Sample Collector

Chemist  
Murshidabad Dist. Lab. P.H.E. Div.

Assistant Engineer (H.Q.)  
Murshidabad Division  
14/03/2020  
नमित्त अध्यक्ष/Nominee Chairman  
वि.प्र.स./V.M.C.  
के. वि. बहरमपुर (प.ब.)  
K.V. BERHAMPORE, W.B.

V.K.P.

प्राचार्य/PRINCIPAL  
केन्द्रीय विद्यालय/KENDRIYA VIDYALAYA  
बहरमपुर/BERHAMPORE-(W.B.)  
मुर्शिदाबाद/MURSHIDABAD  
पिन/PIN-742101

